



PROPOSED FISHWATER FLATS SUBSTATION

JOHN TALLANT ROAD

GRAHAMSTOWN ROAD

Proposed Ducts for Central Crossing

Proposed Ducts for existing Railway Crossing

Notes
Proposed Cable:
 PESTS 240 mm² x 3 Cr 22 KV AI
 Trench: 250 mm wide
 850 mm depth
 Total Length +- 671m
 Cable offset from erf boundary by 1000 mm

- Legend**
- Prop. Joint
 - Prop 22kV Cable
 - Service Cable
 - LV Str Light
 - LV Cable
 - MI Cable
 - Central Crossing ducts
 - FLOOD ZONE
 - QUADRANTAL

Scale
 1:1,250

Drawing Name
 SMARTOPS FISHWATER FLATS SUBSTATION PROPOSED PESTS 22KV CABLES

Drawing No:
 GT0000533

Drawn By: H. PETERSON
 Checked By: Project Leader
 Executive Director
 H. GADLAMBY
 B. BENNISON
 Date: 2013/09/16

Acting Executive Director
 NELSON MANDELA METROPOLITAN MUNICIPALITY ELECTRICITY AND ENERGY BUSINESS UNIT

Appendix 6